

PET RELIEF ROOM, DESIGN INTENT

1.01 DESIGN LAYOUT

- A. Pet Relief Rooms will be located behind the airport security screening area in each Terminal.
- B. Pet Relief Rooms will be accessible from the main public circulation path.
- C. Pet Relief Rooms will not have a water closet, urinal or diaper changing surface.

1.02 MECHANICAL

- A. Pet Relief Rooms will have 15 air changes per hour minimum.

1.03 PLUMBING

- A. To the extent possible, water shut-off valves, temperature control valves, electrical transformers, etc. will be located within 30 horizontal inches of a wall or ceiling access panel.
- B. Alternative location of access panel will be located under the lavatory.

1.04 LIGHTING

- A. Lighting will match the Public Restrooms as described in the Public Restroom, Design Intent.

1.05 ACCESSORIES

- A. The Pet Relief Room will have the following accessories (*in compliance with ADA requirements*):
 - i. Lavatory
 - ii. Soap dispenser
 - iii. Mirror
 - iv. Paper Towel dispenser
 - v. Waste receptacle
 - vi. Dog bag dispenser
 - vii. Dog bag disposal container with lid
 - viii. Hose bib
 - ix. Synthetic grass pet relief area

** To the extent possible, all accessories to be installed on the wall. Floor mounted accessories are not allowed.*

1.06 WALLS

- A. Where feasible, metal stud partitions will be installed on a 6" high concrete curb.
- B. Walls will have waterproofing membrane extend full height from floor to ceiling.
- C. Wall field tile will be full height ceramic tile laid up in a horizontally balanced and consistent pattern from corner to corner and bottom to top. Horizontal stack bond pattern is preferred. Wall field tile will start with a full tile above the wall base tile. Tile color will be **'White'**. Tile grout will be epoxy, color **'White'**.
- D. Stainless steel flush corner guards will match the Public Restrooms as described in the Public Restroom, Design Intent.

1.07 FLOORS

- A. Floor finish will have positive slope to floor drain(s).
- B. All floors will have tile finish. Tile color will be through body **'Medium Grey'**. Tile grout will be epoxy, color to match tile.
- C. Tile cove base will be provided and match floor tile. Non-tile cove bases and cove strips are not acceptable.
- D. Pet relief area will have synthetic grass inserted over tiled floor.
- E. To the extent possible, pet relief area will have passenger activated rinsing system operable by a push button. Rinsing system can be sprinkler(s) in grass area, or soaking system under grass area.

4.0 CEILINGS

- A. Ceiling heights will be 9'-0" minimum above finished floor.
- B. Porous ceiling materials are not acceptable.
- C. Ceiling will be cement plaster or water resistant gypsum board.
- D. All ceilings will be painted white.
- E. All access panels, registers and grills will be painted to match ceiling.

5.0 DOOR

- A. Door design intent to have glazing viewing panel acceptable to current codes.
- B. Door bottom will have minimum 12" high smooth stainless steel kick plate.
- C. Door hardware to include an ADA indicator thumbturn per section 08 71 00 of the Guide Specifications (Design and Construction Handbook).

END OF SECTION